



# HOW TO PREDICT THE VIBRATION EFFECT DUE TO MACHINE OPERATION ON ITS SURROUNDINGS

Alexandre Augusto Simões<sup>1</sup>, Márcio Tadeu de Almeida<sup>2</sup> and Fabiano Ribeiro do Vale Almeida<sup>2</sup>

> <sup>1</sup>Department of Mechanical Engineering, *UNIS* Av. Cel. José Alves, 256, Vila Pinto, Brazil <sup>2</sup>Department of Mechanical Engineering, Federal University of Itajubá Av. BPS, 1303, Brazil <u>mtaev@uol.com.br</u>

#### Abstract

The satisfactory performance of a machine is concerned with its installation, i.e., with a welldesigned foundation and soil investigation. The vibration amplitude of the machinefoundation system must be kept under permissible values generally specified by the machine's manufacturers and natural frequencies must be determined to avoid resonance. There may be situations when amplitudes of the machine may be within the acceptable limits for satisfactory machine operation but the vibrations may affect other machines around, be harmful to adjacent structures and precision equipment and annoying to persons. Here in will be shown how to predict in a simple way the effect of the vibration due to the machine operation on its surroundings considering the foundation as a vibration source on the surface of an elastic medium.

#### **1. INTRODUCTION**

All machines generated unbalanced dynamic loads (forces and moments) that induce vibrations. These dynamic loads are caused by machine operation condition such as wear, imbalance, misalignment, etc, and must be kept under a safety limit by the maintenance personal for the satisfactory operation of the entire plant. Another machine's vibration problem is caused by resonance. The resonance condition is reached when one or more frequencies of the exciting loads are near or equal to any of the natural frequencies of the machine-foundation-soil system. Unfortunately the resonance problem can't be readily solved because a structural modification will be necessary to bring the vibration level to accepted values. The vibration generated by the machine operation condition is then transmits through the soil by the block foundation what may affect the vicinity in a bad way. A vibrating footing is then a source of wave generation in the soil. Herein the response of a block foundation embedded in the soil and excited by a vertical harmonic load will be outlined and used to predict vibration response of the foundation. Also the problem of the vibration propagation through the soil due to concentrated dynamic load acting on the soil surface will be treated to

estimated the decrease in amplitude of the vibration with distance from the source and to evaluated the effects of the vibration on the performance of other equipments in the vicinity and structures around

## 2. VIBRATION PROPAGATION THROUGH THE SOIL DUE TO PERIODIC CONCENTRATED LOAD

The problem of the surface wave propagation in an elastic medium (elastic half-space) was first studied by Lord Rayleigh [7] and is known as the *Rayleigh* wave. Later Lamb [6] studies the response of the medium as it was excited by oscillating vertical force or pulse loading acting at a point or along a line on the surface and within the body. See Figure (1).

Lamb's solutions for calculation of vertical surface displacement at a distance r from the concentrated dynamic load on the surface of the medium may be written as following,

$$w = \frac{Pe^{i\omega t}}{Gr} (F_1 + iF_2)$$
(1)

in which, P = amplitude of the concentrated oscillating force applied to surface area,

 $\omega$  = circular frequency of force application, G = shear modulus of the ground,

r = radial distance from the load, i = imaginary number,  $F_1$ ,  $F_2$  = dimensionless Dynamic Boussinesq Displacement Functions and given by the following equations,



Figure 1. Dynamic concentrated load applied to soil surface and wave propagation through the soil.

$$F_{1} = \frac{a}{2\pi} \left[ \pi y K_{d} Y_{O}(ay) + \int_{0}^{s} \frac{x(s^{2} - x^{2})^{0.5} Y_{O}(ax)}{(2x^{2} - 1) + 4x^{2}(s^{2} - x^{2})^{0.5}(1 - x^{2})^{0.5}} dx + \int_{0}^{1} \frac{4x^{3}(x^{2} - s^{2})(1 - x^{2})^{0.5} Y_{O}(ax)}{(2x^{2} - 1)^{4} - 16x^{4}(x^{2} - s^{2})(x^{2} - 1)} dx + \frac{2}{\pi} \int_{0}^{\infty} \frac{x(s^{2} - x^{2})^{0.5} K_{O}(ax)}{(2x^{2} - 1)^{2} - 4x^{2}(s^{2} - x^{2})^{0.5}(1 - x^{2})^{0.5}} dx \right]$$

$$(2)$$

$$-F_{2} = \frac{\alpha}{2\pi} \left[ \pi y K_{d} J_{O}(ay) + \int_{0}^{\infty} \frac{x(3-x-1)}{(2x^{2}-1) + 4x^{2}(s^{2}-x^{2})^{0.5}(1-x^{2})^{0.5}} dx + \int_{0}^{\infty} \frac{4x}{(2x^{2}-1)^{4} - 16x^{4}(x^{2}-s^{2})(x^{2}-1)} dx \right]$$
(3)

in which, a is the dimensionless frequency and is defined by the following equation where  $\rho$  is the soil mass density,

$$a = \omega r \sqrt{\frac{\rho}{G}}$$
(4)

v is the Poisson's ratio of the soil and the *s* parameter is given by the equation below,

$$s = \sqrt{\frac{1-2\nu}{2(1-\nu)}},\tag{5}$$

 $J_O$ , is the Bessel function of the first kind and order zero;  $Y_O$ , is the Bessel function of second kind and order zero;



Figure 2. Surface displacement of an elastic medium due to an oscillating concentrated load with amplitude P=1(N) and a circular frequency  $\omega = 62.83$  (rad/s) or f=10(Hz). Soil data: G=  $3.2 \times 10^7$  (N/m<sup>2</sup>); mass density  $\rho=1800$  (kg/m<sup>3</sup>); Poisson's ratio v=0.3. Rayleigh velocity V<sub>R</sub>=123.7 (m/s) and wavelength  $\lambda=12.4$  (m).

 $K_O$ , is the Modified Bessel function of order zero; y is the positive real root of the equation below and is a function of Poisson's ratio v only,

$$(2y2 - 1)2 - 4y2(y2 - s2)0.5(y2 - 1)0.5 = 0$$
(6)

 $K_d$ , is a function of the Poisson's ration v and the value for y of Equation (6) and is expressed by Equation (7).

$$K_{d} = \frac{-(y^{2} - s^{2})^{0.5}}{8y(2y^{2} - 1) - \frac{4y(4y^{4} - 3y^{2}(s^{2} + 1) + 2s^{2})}{(y^{2} - s^{2})^{0.5}(y^{2} - 1)^{0.5}}}$$
(7)

A plot of the surface displacement caused by a unit-oscillating load with a circular frequency  $\omega = 62.8$  (rad/s) is shown in Figure (2). In this figure is possible to see how the amplitude of the surface wave decreases with the distance from source. The dimensionless functions F<sub>1</sub> and F<sub>2</sub> were numerically evaluated using the trapezoidal method. The surface wave, also known as Rayleigh wave, travels at a speed given by the equation below.

$$V_{\rm R} = \frac{V_{\rm S}}{y} \tag{8}$$

in which, y is the value obtained using the Equation (6);  $V_S$  is the shear velocity given by the Equation (9).



Figure 3. Schematic of a block foundation embedded in a soil and subjected to a periodic force F(t).

$$V_{\rm S} = \sqrt{\frac{\rm G}{\rho}} \tag{9}$$

### 3. VIBRATION OF A RIGID BLOCK FOUNDATION EMBEDDED ON THE SOIL

The rigid block that supports machines may be of various kinds and is usually embedded on the soil as shown in Figure (3). The problem of a vibrating rigid circular footing on the surface of an elastic medium was examined first by Reissner [10] and after by Sung [12] and Quinlan [9]. The solutions were modified for the purpose to obtain a solution for vertical vibrations similar to the equation for damped vibrations of a single degree of freedom system. See Figure (4). The vertical stiffness,  $k_{ZS}$ , and damping,  $c_{ZS}$ , for an embedded foundation are given by the following equations below (Prakash and Puri [8], Novak and Beredugo [2], Richart *et al* [11]).

$$k_{ZS} = Gr_O \left( C_1 + \frac{G_S}{G} \frac{p}{r_O} S_1 \right)$$
(10)

$$c_{ZS} = \frac{Gr_0}{\omega} \left( C_2 + \frac{G_S}{G} \frac{p}{r_0} S_2 \right)$$
(11)

Here,  $C_1$  and  $C_2$  are dimensionless parameters derived from the soil reaction at the base of the foundation, and  $S_1$  and  $S_2$  are parameters derived from the reactions acting on the sides of the block foundation. G and  $\rho$  are respectively the shear modulus and the mass density of the soil layer under the base of the foundation;  $G_S$  and  $\rho_S$  are the shear modulus and the mass density of the layer surrounding the sides of the block foundation as shown in Figure (3). The parameter p is the embedment depth. If the footing is circular,  $r_0$  is the radius of the footing. In the case of a rectangular, square, or other footing shape of area  $A_b$  the equivalent radius  $r_0$ is given by Equation (12). The parameters  $C_1$  and  $C_2$  depend on the depth H of the soil, Poisson's ratio v, and the dimensionless frequency  $a_0$  given by Equation (13). The parameters  $S_1$  and  $S_2$  depend only on the dimensionless frequency  $a_0$ .

$$r_{\rm O} = \sqrt{\frac{A_{\rm b}}{\pi}} \tag{12}$$

$$a_{\rm O} = \frac{\omega r_{\rm O}}{V_{\rm S}} \tag{13}$$



Figure 4. Schematic of a one degree-of-freedom model of a machine-foundation system.

The vertical amplitude  $w_0$  of the steady-state response of a single-degree-of-freedom system with respect to the harmonic forcing function F(t) is given by Equation (14).

$$w_{0} = \frac{\frac{P}{k_{ZS}}}{\sqrt{(1 - \Omega^{2})^{2} + (2\xi\Omega)^{2}}}$$
(14)

in which, *P* is the amplitude of the harmonic forcing function F(t) as shown in Figure (3) and  $\Omega$  is the frequency ratio defined by the following expression,

$$\Omega = \frac{\omega}{\omega_{\rm n}} = \frac{\omega}{\sqrt{\frac{k_{ZS}}{M}}}$$
(15)

where  $\omega_n$  is the natural frequency and *M* is the total mass, i. e., the mass of the inertial block and the equipment.  $\xi$  is the damping ratio defined by the expression below,

$$\xi = \frac{c_{ZS}}{2\omega_{\rm p}M} \tag{16}$$

### 4. DEPENDENCE OF THE AMPLITUDE OF SOIL VIBRATION ON DISTANCE FROM THE SOURCE OF WAVES

A vibrating machine foundation generates waves in the soil. The energy of the oscillating footing is carried away by a combination of waves: the compression wave, shear wave and the Rayleigh wave. The energy density of each one of these waves decreases with distance from the footing. Figure (2) shows the decrease in amplitude of the wave with increased distance when a concentrated vertical load is applied at the surface of an elastic medium. The decrease in amplitude, as shown in Figure (2), can be expressed by the suggested expression below (Richart *et al* [11], Barkan [1]).

$$w = w_1 \sqrt{\frac{d}{\chi}}$$
(17)

where, *w* is the unknown amplitude at a distance  $\chi$  from the source; *w*<sub>1</sub> is the known amplitude at distance d from source;



Figure 5. Schematic of active (left side) and passive (right side) isolation problem.

### 5. EFFECT ON SURROUNDING OF WAVES FROM INDUSTRIAL SOURCES

If a machine is directly attached to its block foundation, the vibration generated due to the normal operating condition of the machine is transmitted through the soil and may affect the performance of other machines in the vicinity or be harmful to adjacent structures even at large distance. On the other hand, it is sometimes possible to isolate the source of vibration from its surroundings (active isolation), or to isolate a device in such a way that the motion of its base caused by a disturbing source in the vicinity is reduced to acceptable limits (passive isolation). See Figure (5).Herein, the problem of how to predict the effect due to the machine operation on its vicinity was analyzed considering three cases.

First, the problem was treated without the presence of isolation mounts, i.e., without active and passive isolators. In this case the machine was considered directly attached to the foundation and a single degree of freedom model was used to determine the amplitude of vibration of the machine and its foundation. The problem was solved applying Equation (14) with  $Z_1=Z_2=w_0$ . See Figure (6) for more details. Equation (17) was modified to take in account the vibration attenuation with distance due to dispersion of the wave energy. The calculated vibration amplitude of the machine block foundation was considered as the known vibration amplitude at a distance d =  $r_0$ . In this way, the Equation (17) becomes,

$$Z_3 = w_1 \sqrt{\frac{r_0}{r_0 + b}}$$
(18)

In this case  $w_1=Z_1=Z_2$  and  $Z_3=Z_4$  due to the absence of passive and active isolators. A distance of b=1.5(m) was considered. See Figure (5) or Figure (6). In the second case only active isolation was considered and a two-degree of freedom system was required to solve this problem. See Figures (5) and (7). In this second case is necessary to consider  $w_1=Z_2$  in Equation (18) and as in the first case  $Z_3=Z_4$  due to the absence of passive isolators.



Figure 6. Schematic of the first case treated, i.e., without the presence of active and passive isolation mounts.



Figure 7. Schematic of the two degree of freedom of the system showing the machine with its active isolators and the block foundation with its equivalent soil stiffness and damping.

Finally both the active and passive isolators were applied. In this last case the transmissibility displacement ratio must be calculated using Equation (19) below (Inman [5]).

$$\frac{Z_4}{Z_3} = \left[\frac{1 + (2\xi_p \Omega_p)^2}{(1 - \Omega_p^2)^2 + (2\xi_p \Omega_p)^2}\right]^{1/2}$$
(19)

In Equation (19),  $\xi_p$  is the damping ratio of the passive isolator and  $\Omega p$  is the frequency ratio of the frequency of the oscillatory base motion  $\omega_b$  to the natural frequency of the passive isolation system  $\omega_{np}$ . The frequency of the base motion is equal to the frequency of the excitation,  $\omega_b = \omega$ . Table 1 presents the data required to the computation. The results of the computation of each one of the cases is shown in Table 2. The force amplitude used to excited the system was P=1500(N) at  $\omega$ =188.5 (rad/s). The values to the natural frequency and damping ratio of the active and passive isolators were chosen to be equals to 5(Hz) and 0.05(/), respectively.

#### **6. CONCLUSION**

In the industry the problem of vibration is always of first concern and must be kept below permissible values for satisfactory operation of the entire plant. The goal of this paper was to predict the influence of the vibration in the vicinity due to operation condition of the machine in a simple way and aid the engineer to get some previous design requirements or remedial measures, in a low cost manner, by proper selection of the block size and contact area, active and passive isolators. The problem of the vibration propagation through the soil due to concentrated dynamic load acting on the soil surface was treated and the results showed that the vibration attenuation with distance due to dispersion of the wave energy may be approximated by Equation (17) and used to estimated the vibration level that affect structures and delicate machines around as well cause discomfort to workers.

	ek bize and mass, machine auta,	dynamic son parameters
	Shear modulus	$G=3.14 \times 10^7 (N/m^2)$
Soil Data	Mass density	$\rho = 1650 (kg/m^3)$
	Poisson's ratio	v=0.25 (/)
	Lengthxwidthxthickness	1.50mx0.80mx0.60m
Block Size	Embedded depth	p=0.5m
and its mass	Block foundation Mass	$M_{\rm B} = 1728 \; ({\rm kg})^*$
Machine Data	Equipment Mass	$M_{\rm E} = 300 \; (\rm kg)$
	Speed	1800 rpm (30Hz)
Dynamic Soil Parameters	r <sub>o</sub>	0.62m
	k <sub>ZS</sub>	$1.34 \mathrm{x} 10^8 \mathrm{(N/m)}$
	c <sub>ZS</sub>	$7.8 \times 10^5 (Ns/m)$
<u> ቀ ጥ1 11 1 ር 1</u>	. 1 1 . 1 .	1 ( I <sup>1</sup> )

Table 1. Soil, Block Size and Mass, Machine data, dynamic soil parameters

\* The block foundation mass was calculated using the concrete mass density equal to 2400 kg/m<sup>3</sup>

unce speeme cuses.		
First Case: without t	the presence of isolation	
mounts		
$Z_1 = Z_2 = w_0$	10(µm)	
$Z_3 = Z_4$	5.4(µm)	
Second Case: active isolation		
$Z_1$	140(µm)	
$Z_2$	0.3(µm)	
$Z_3 = Z_4$	0.16 (µm)	
Third Case: active and passive isolation		
$Z_1$	140(µm)	
$Z_2$	0.3(µm)	
Z <sub>3</sub>	0.16 (µm)	
$Z_4$	0.0053 (µm)	

Table 2. Amplitudes  $Z_1$ ,  $Z_2$ ,  $Z_3$ ,  $Z_4$  of the vibratory movements of the system shown in Fig. 5 to three specific cases.

The vibration problem of footings resting on or embedded on the soil was treated here considering the solutions given in literature to a circular footing with radius r<sub>0</sub>. For the case of a square and rectangular contact area is acceptable to use solutions of a rigid circular contact area as was done herein for approximate response calculations (Prakash and Puri [8], Novak and Beredugo [2], Richart et al [11]). Solutions for irregular shapes of the foundation are available and must be found in the literature (Gazetas [4]). Also Models with several degrees of freedom may be used for predicting the interaction of the machine with its foundation. The interaction changes the rotor-bearing critical speeds predicted by the manufacturer what may causes excessive vibration of the system (Chen [3]). The results obtained and presented in Table 2 shows that when a machine is rigidly bolted to floor or its block foundation, the vibration of the machine itself may be reduced compared to the case when active isolators are used. The use of active isolators reduces the vibration transmitted through the soil what will reduce the bad effects of the vibration on its vicinity. So, when active mounts are provided the vibration transmitted to the soil will be reduced but this may cause significant vibration to the machine during its operation or even during its starting and stopping stages. The use of passive isolation helps to reduce the effect of the vibration and is also possible to provide isolation using wave barriers or trench barriers (Prakash and Puri [8], Richart et al [11]).

#### REFERENCES

- [1] D.D. Barkan, Dynamic of Bases and Foundations, McGraw Hill Book Company, Inc, 1962.
- [2] Y.O. Beredugo, M. Novak, Vertical Vibration of Embedded Footings, *Journal of the Soil Mechanics and Foundations Division*, 1972.
- [3] H.M. Chen, S.B. Malanoski, Fan/Foundation Interaction A Simplified Calculation Procedure, *Journal of Engineering for Power*, Vol. 103, pp. 805-810, 1981.
- [4] G. Gazetas, *Foundation Vibrations, Foundation Engineering Handbook*, 2<sup>nd</sup> Edition, H. Y. Fang Ed., Van Nostrand Reinholds, Chapter 15, pp. 553-593, 1991.
- [5] D.J. Inman, Engineering Vibration, Prentice-Hall International, Inc, 1994.
- [6] H. Lamb, On the Propagation of Tremors Over the Surface of An Elastic Solid, *Philosophical Transactions* of the Royal Soc., London, 1904.
- [7] Lord Rayleigh, On Waves Propagated Along the Plane Surface of An Elastic Solid, *London Mathematical Soc. Proceedings*, 1885.
- [8] S. Prakash, V.K. Puri, Foundation for Machines Analysis and Design, John Wiley & Sons, Inc, 1988.
- [9] P.M. Quinlan, P. M., The Elastic Theory of Soil Dynamics, Symposium on Dynamic Testing of Soils, ASTM Special Technical Publication No 156, pp. 3-34, 1953.
- [10] E. Reissner, Stationare, Axialsymmetriche durchein Schuttelude Masse erregte Schwingungen eines Homogenen Elastischen Halbraumes, *Igenieur-Archiv*, Vol. 7, 1936.
- [11] F.E. Richart, R.D. Woods, J. Hall, Vibrations of Soil and Foundations, Prentice Hall, Inc, 1970.
- [12] T.Y. Sung, Vibrations in Semi-Infinite Solids due to Periodic Surface Loading, *Symposium on Dynamic Testing of Soils*, ASTM Special Technical Publication No 156, pp. 35-64, 1953.